



## ADDENDUM NUMBER TWO

March 9, 2018

**RFQ #18-910-16**

### **SUPPLY AND INSTALL SECURITY CAMERA SYSTEMS AT THE FLORIDA NEW HOUSING COMMUNITY**

THE FOLLOWING ADDENDUM IS BEING ISSUED TO INCORPORATE THE FOLLOWING IN THE REFERENCED REQUEST FOR QUOTES.

#### **ITEM #1 WRITTEN QUESTIONS RECEIVED**

**Q1: Is a scale drawing of the site available, which is needed to determine cable distances?**

A1: Site drawings will be available for viewing on Tuesday, March 13, 2018, from 9:00 A.M. until 2:30 P.M., at the Housing Authority of New Orleans, 4100 Touro Street, New Orleans, LA 70122, in the Procurement and Contracts Department Conference Room.

The drawings do not include dimensions and are offered for informational purposes only. Respondents are responsible for determining the actual quantities required to complete the Scope of Work.

**Q2: Fiber optic cable is not specified for this project, but may be required due to the 330 ft. distance limitations on CAT 6 cable. Please comment.**

A2: The camera systems must be fully operable upon completion of the project. The quote amount shall include the installation of an Ethernet network with a single-mode fiber optic network trunk, delivering 2 strands of fiber, with SC connector ends to each camera bank, a SC-fiber to copper media converter to each camera, as well as all in-ground and above ground components required to connect the cameras back to the head end unit. Along with the details of the installation found in the Scope of Work, the price quoted shall reflect the purchase of all necessary fiber and Ethernet cable, all required in-ground conduit, in-ground housing for fiber splices, all necessary conduit, molding, and raceway for internal and external cable and connectors, SC fiber and Ethernet connectors, as well as the necessary media converters to complete the project.

**Quotes must be received by the Housing Authority of New Orleans (HANO) in the Office of Procurement and Contracts by 2:00 p.m., local time on Friday, March 16, 2018. All terms and conditions shall remain as stated in the original Request for Quotes. All addenda must be acknowledged.**

**END OF ADDENDUM NUMBER TWO**